Rectangular Inductive Long-Distance Proximity

AS Series (DC 4-wire)

INSTRUCTION MANUAL

TCD210254AC

Autonics

Thank you for choosing our Autonics product.

Read and understand the instruction manual and manual thoroughly before using the product.

For your safety, read and follow the below safety considerations before using. For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website.

Keep this instruction manual in a place where you can find easily.

The specifications, dimensions, etc. are subject to change without notice for product improvement. Some models may be discontinued without notice.

Follow Autonics website for the latest information.

Safety Considerations

- Observe all 'Safety Considerations' for safe and proper operation to avoid hazards.
- A symbol indicates caution due to special circumstances in which hazards may occur.

Warning Failure to follow instructions may result in serious injury or death.

- 01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss. (e.g. nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.) is instruction may result in personal injury, economic loss or
- 02. Do not use the unit in the place where flammable/explosive/corrosive gas, high humidity, direct sunlight, radiant heat, vibration, impact, or salinity may be present.

ure to follow this instruction may result in explosion or fire.

- 03. Do not disassemble or modify the unit.
- ailure to follow this instruction may result in fire
- 04. Do not connect, repair, or inspect the unit while connected to a power

Failure to follow this instruction may result in fire

05. Check 'Connections' before wiring.

Failure to follow this instruction may result in fire.

↑ Caution Failure to follow instructions may result in injury or product damage.

- 01. Use the unit within the rated specifications.
- 02. Use a dry cloth to clean the unit, and do not use water or organic solvent.

Cautions during Use

- Follow instructions in 'Cautions during Use'. Otherwise, it may cause unexpected
- 12-48 VDC == power supply should be insulated and limited voltage/current or Class 2, SELV power supply device.
- Use the product, after 0.8 sec of supplying power.
- Wire as short as possible and keep away from high voltage lines or power lines, to prevent surge and inductive noise. Do not use near the equipment which generates strong magnetic force or high frequency noise (transceiver, etc.). In case installing the product near the equipment which generates strong surge (motor,
- welding machine, etc.), use diode or varistor to remove surge.
- This unit may be used in the following environments. - Indoors (in the environment condition rated in 'Specifications')
- Altitude max. 2,000 m
- Pollution degrée 2
- Installation category II

Cautions for Installation

- Install the unit correctly with the usage environment, location, and the designated specifications.
- Do NOT impacts with a hard object or excessive bending of the wire lead-out. It may cause damage the water resistance.
- Do NOT pull the Ø 2.5 mm cable with a tensile strength of 20 N, the Ø 4 mm cable with a tensile strength of 30 N or over and the Ø 5 mm cable with a tensile strength of 50 N or over. It may result in fire due to the broken wire.
- When extending wire, use AWG 22 cable or over within 200 m.
- Tighten the installing screws with under 1.47 N m torque

Ordering Information

This is only for reference, the actual product does not support all combinations. For selecting the specified model, follow the Autonics website.

AS 0 O Dimension

- 0 0 0

O Power supply

Number: A side length(unit: mm) Sensing distance

Number: Standard sensing distance N3: NPN Normally Open + Normally Closed (unit: mm)

D: 12 - 48 VDC==

Control output


P3: PNP Normally Open + Normally Closed


Product Components

- $\bullet \; \mathsf{Product} \times 1$
- M5 Bolt × 4
- Instruction manual \times 1

Connections


■ Cable type






■ Inner circuit (NPN output)

■ Inner circuit (PNP output)



LOAD LOAD N.C.



Operation Timing Chart

		Normally open			Normally closed		
Sensing target		Presence			Presence		
		Nothing -			Nothing		
Load		Operation			Operation		
		Return -			Return		
Output voltage	NPN	нг			Н		
	output	L			L		
	PNP	Н			Н		
	output	L-			L		
Operation indicator (yellow)		ON			ON		
		OFF -			OFF		


Specifications

AS80-50D□			
A360-30D			
80 mm			
50 mm			
0 to 35 mm			
≤ 15 % of sensing distance			
150 × 150 × 1 mm			
30 Hz			
$\pm~10~\%$ for sensing distance at ambient temperature 20 °C			
Power indicator (green), operation indicator (yellow)			
C€ R ENI			
≈ 470 g			

2 times of the standard sensing target, 1/2 of the sensing distance for the distance.

Power supply	12 - 48 VDC== (ripple P-P: ≤ 10 %), operating voltage: 10 - 65 VDC==				
Current consumption	≤ 20 mA				
Control output	≤ 200 mA				
Residual voltage	≤2V				
Protection circuit	Surge protection circuit, output short over current protection circuit, reverse polarity protection				
Insulation type	\geq 50 M Ω (500 VDC== megger)				
Dielectric strength	Between the charging part and the case: 1,500 VAC \sim 50/60 Hz for 1 minute				
Vibration	1 mm double amplitude at frequency 10 to 55 Hz in each X, Y, Z direction for 2 hours				
Shock	500 m/s² (≈ 50 G) X, Y, Z directions for 3 times				
Ambient temperature	-25 to 70 °C, storage: -30 to 80 °C (no freezing or condensation)				
Ambient humidity	35 to 95 %RH, storage: 35 to 95 %RH (no freezing or condensation)				
Protection structure	IP67 (IEC standard)				
Connection	Cable type model				
Wire spec.	Ø 5 mm, 4-wire, 2 m				
Connector spec.	AWG 22 (0.08 mm, 60-core), insulator diameter: Ø 1.25 mm				
Material	Case: PC+ABS, standard type cable (black): polyvinyl chloride (PVC)				

• Unit: mm, For the detailed dimensions of the product, follow the Autonics web site




Setting Distance Formula

Detecting distance can be changed by the shape, size or material of the target.

For stable sensing, install the unit within the 70 % of sensing distance

Setting distance (Sa) = Sensing distance (Sn) × 70 %




Mutual-interference & Influence by Surrounding Metals

■ Mutual-interference

When plural proximity sensors are mounted in a close row, malfunction of sensor may be caused due to mutual interference.

Therefore, be sure to provide a minimum distance between the two sensors, as below



■ Differential frequency

When sensors are mounted on metallic panel, it must be prevented sensors from being affected by any metallic object except target. Therefore, be sure to provide a minimum distance as below chart.



